



FT1 Insertion Flow Meter
MODEL CODES

399 Reservation Road
Marina, CA 93933
831-384-4300
www.foxthermal.com
sales@foxthermal.com

MODEL FT1 INSERTION METER

	Code	Description
Parent Model No.*	FT1	Insertion Mass Flow meter; 4 to 20 mA and USB outputs standard
Feature 1: Probe*	06I	Insertion meter with 6-inch probe
<div style="border: 1px dashed black; padding: 5px; margin-bottom: 5px;">See "Calculating Probe Lengths" Below</div> <div style="border: 1px dashed black; padding: 5px;">Compression fitting included at no charge</div>	09I	Insertion meter with 9-inch probe
	12I	Insertion meter with 12-inch probe
	15I	Insertion meter with 15-inch probe
	18I	Insertion meter with 18-inch probe
	24I	Insertion meter with 24-inch probe
	30I	Insertion meter with 30-inch probe
	36I	Insertion meter with 36-inch probe
	15R	15" Probe w/ 150 PSI retractor & full port valve - 1" male NPT, 316 SS wetted parts
	18R	18" Probe w/ 150 PSI retractor & full port valve - 1" male NPT, 316 SS wetted parts
	24R	24" Probe w/ 150 PSI retractor & full port valve - 1" male NPT, 316 SS wetted parts
30R	30" Probe w/ 150 PSI retractor & full port valve - 1" male NPT, 316 SS wetted parts	
36R	36" Probe w/ 150 PSI retractor & full port valve - 1" male NPT, 316 SS wetted parts	
Feature 2: Display*	D0	No Display and Configuration Panel
	DD	Include Rate/Total Display & Configuration Panel
Feature 3: Outputs*	P1	4 to 20mA + Pulse Output
	BH	4 to 20mA/HART + Pulse Output
	RS	4 to 20mA + RS 485 (Modbus RTU or BACnet MS/TP - Field selectable)

OPTIONS

Part #	Description
999992	Certificate of Conformance
999995	Certificate of Origin
106012	Extra instruction manual
100657	Stainless Steel Tags
106415	Teflon Ferrule Kit, 60 PSI max.

OPTIONS

Part#	Description
890000	Flow meter cleaned and bagged for Oxygen service
104870	USB Cable, A-male/mini USB-B male, 6 feet
106728	24VDC power supply with DIN mounting rail
106658	Conduit Entry Adapter, 3/4" NPT to M20x1.5, qty. 2 required per meter

NOTES: * The Parent Model Number and one of each Feature must be specified.
Example: FT1-09I-DD-RS

Insertion flow meters can be installed in 1.5" pipes or larger.
Calculating Probe Length: position the Fox Sensor in the center of the pipe. Use the following to calculate the probe length:
Probe Length = 1/2 pipe diameter (D) + 3" + insulation + retractor (for codes 15R through 36R, add 10"). Round up to next larger probe available.
D = pipe diameter; Insulation = Thickness of insulation (if any); Retractor = Dimension of retractor (10"), if supplied.
Example 1: Pipe ID = 10", no insulation or retractor: 5" + 3" = 8". Round up to 9" probe (09I).
Example 2: Pipe ID = 10" with retractor, no insulation: : 5" + 3" + 10"(retractor) = 18" (18R probe with retractor).

MODEL FT1 INLINE METER

Feature Codes	Code	Description
Parent Model No.*	FT1	Inline Mass Flow Meter
Feature 1 : Flow Body Size*		316 Stainless steel flow body
	075P	0.75 inch flow body, male NPT ends (schedule 40) 12" Face to Face
	10P	1 inch flow body, male NPT ends (schedule 40) 12" Face to Face
	125P	1.25 inch flow body, male NPT ends (schedule 40) 12" Face to Face
	15P	1.5 inch flow body, male NPT ends (schedule 40) 12" Face to Face
	20P	2 inch flow body, male NPT ends (schedule 40) 12" Face to Face
	25P	2.5 inch flow body, male NPT ends (schedule 40) 18" Face to Face
	30P	3 inch flow body, male NPT ends (schedule 40) 18" Face to Face
	075F	0.75 inch flow body, 150# RF flanges (schedule 40) 12" Face to Face
	10F	1 inch flow body, 150# RF flanges (schedule 40) 12" Face to Face
	125F	1.25 inch flow body, 150# RF flanges (schedule 40) 12" Face to Face
	15F	1.5 inch flow body, 150# RF flanges (schedule 40) 12" Face to Face
	20F	2 inch flow body, 150# RF flanges (schedule 40) 12" Face to Face
	25F	2.5 inch flow body, 150# RF flanges (schedule 40) 18" Face to Face
	30F	3 inch flow body, 150# RF flanges (schedule 40) 18" Face to Face
	40F	4 inch flow body, 150# RF flanges (schedule 40) 18" Face to Face**
	60F	6 inch flow body, 150# RF flanges (schedule 40) 24" Face to Face**
		A106 Grade B Carbon steel pipe (+ A105 flanges - if ordered)
	20PC	2 inch, male NPT ends (schedule 40) 12" Face to Face
	25PC	2.5 inch, male NPT ends (schedule 40) 18" Face to Face
	30PC	3 inch, male NPT ends (schedule 40) 18" Face to Face
	20FC	2 inch, 150# RF flanges (schedule 40) 12" Face to Face
	25FC	2.5 inch, 150# RF flanges (schedule 40) 18" Face to Face
	30FC	3 inch, 150# RF flanges (schedule 40) 18" Face to Face
	40FC	4 inch, 150# RF flanges (schedule 40) 18" Face to Face **
	60FC	6 inch, 150# RF flanges (schedule 40) 24" Face to Face **
Feature 2: Display*	D0	No Display and Configuration Panel
	DD	Include Rate/Total Display & Configuration Panel
Feature 3: Outputs*	P1	4 to 20mA + Pulse Output
	BH	4 to 20mA/HART + Pulse Output
	RS	4 to 20mA + RS 485 (Modbus RTU or BACnet MS/TP - Field selectable)

OPTIONS

Part#	Description
890000	Flow meter cleaned and bagged for Oxygen service
999995	Certificate of Origin
106012	Extra Instruction Manual
100657	Stainless Steel Tags
999992	Certificate of Conformance
106415	Teflon Ferrule Kit, 60 psi max.
106658	Conduit Entry Adapter, 3/4" NPT to M20x1.5, qty. 2 required per meter
106728	AC to 24VDC Power converter with DIN mounting rail
104870	USB Cable, A-male/mini USB-B male, 6 feet

Notes: * The Parent Model Number and one of each Feature must be specified.
Example: FT1-10P-D0-P1

** Above 2,500 SCFM (4,250 NM3H) consult factory for calibration charge.